

1
2
3
4 BILL NO. S-77-11- 45

5 SPECIAL ORDINANCE NO. S- 274-77

6 AN ORDINANCE approving a blanket purchase
7 order for materials for the Water Main-
8 tenance and Service Department.

9
10 BE IT ORDAINED BY THE COMMON COUNCIL OF THE CITY OF FORT
11 WAYNE, INDIANA:

12 SECTION 1. That the contract dated October 31, 1977,
13 between the City of Fort Wayne, by and through its Mayor and the
14 Board of Public Works and Cooper Distributing Co., Inc., City
15 Utilities Purchase Order No. 9364, for a blanket order for fire
16 hydrants requirements for 1978, all for a estimated maximum cost
17 of \$48,600.00 to be charged against Water Maintenance and Service
18 Department as the supplies are needed, which said purchase order
19 is on file in the Office of the Department of Purchasing and is
20 by reference incorporated herein, made a part hereof and is hereby
21 in all things ratified, confirmed and approved.

22 SECTION 2. This Ordinance shall be in full force and
23 effect from and after its passage and approval by the Mayor.

24
25
26
27
28
29
30
31
32
33
34
35

Councilman

APPROVED AS TO FORM
AND LEGALITY.


CITY CLERK

Read the first time in full and on motion by Burns, seconded by Hunter, and duly adopted, read the second time by title and referred to the Committee on City Utilities (and the City-Plan Commission for recommendation) and Public Hearing to be held after due legal notice, at the Council Chambers, City-County Building, Fort Wayne, Indiana, on _____, the _____ day of _____, 19____ at _____ o'clock _____ M., E.S.T.

DATE: 11-22-77

Charles W. Westerman
CITY CLERK

Read the third time in full and on motion by Burns, seconded by Hinga, and duly adopted, placed on its passage.
PASSED (~~LOST~~) by the following vote:

	<u>AYES</u>	<u>NAYS</u>	<u>ABSTAINED</u>	<u>ABSENT</u>	<u>TO-WIT:</u>
<u>TOTAL VOTES</u>	<u>8</u>	<u>0</u>	_____	<u>1</u>	_____
<u>BURNS</u>	<u>X</u>	_____	_____	_____	_____
<u>HINGA</u>	<u>X</u>	_____	_____	_____	_____
<u>HUNTER</u>	<u>X</u>	_____	_____	_____	_____
<u>MOSES</u>	<u>X</u>	_____	_____	_____	_____
<u>NUCKOLS</u>	<u>X</u>	_____	_____	_____	_____
<u>SCHMIDT, D.</u>	<u>X</u>	_____	_____	_____	_____
<u>SCHMIDT, V.</u>	_____	_____	_____	<u>X</u>	_____
<u>STIER</u>	<u>X</u>	_____	_____	_____	_____
<u>TALARICO</u>	<u>X</u>	_____	_____	_____	_____

DATE: 12-13-77

Charles W. Westerman
CITY CLERK

Passed and adopted by the Common Council of the City of Fort Wayne, Indiana, as
(ZONING MAP) (GENERAL) (ANNEXATION) (SPECIAL) (APPROPRIATION) ORDINANCE
(RESOLUTION) No. 1274-77 on the 13th day of December, 1977
ATTEST: (SEAL)

Charles W. Westerman
CITY CLERK

John Nuckols
PRESIDING OFFICER

Presented by me to the Mayor of the City of Fort Wayne, Indiana, on the 14th day of December, 1977, at the hour of 11:00 o'clock A M., E.S.T.

Charles W. Westerman
CITY CLERK

Approved and signed by me this 16th day of December, 1977,
at the hour of 1:00 o'clock _____ M., E.S.T.

Robert Armstrong
MAYOR

Bill No. S-77-11-45

REPORT OF THE COMMITTEE ON CITY UTILITIES

We, your Committee on City Utilities to whom was referred an Ordinance
approving a blanket purchase order for materials for the Water Maintenance
and Service Department

have had said Ordinance under consideration and beg leave to report back to the Common
Council that said Ordinance do PASS.

PAUL M. BURNS - CHAIRMAN

FREDRICK R. HUNTER - VICE CHAIRMAN

VIVIAN G. SCHMIDT

WINFIELD C. MOSES, JR.

JAMES S. STIER

Paul M. Burns

Fredrick R. Hunter

Winfield C. Moses, Jr.
James S. Stier

12-13-77
DATE 12-13-77 CHARLES W. WESTERMAN, CITY CLERK

Memorandum

To H. P. Wehrenberg, Board of Works

Date October 31, 1977

From Ruth Winget, Purchasing Department

Subject Bid Reference No. 447, 150 Fire Hydrants (1978 Requirements)

COPIES TO:

R. Walker
B. Drew
V. Sheldon

Attached are documents relating to the subject bid and Purchase Order No. B-9364.

It is recommended by the Water Maintenance & Service Dept. and Purchasing that the Cooper Distributing Co. bid be accepted.

Offerings were submitted as shown on the attached tabulation.

The Treaty Company bid includes the following statement:

"Note: Our prices firm through April 1, 1978. Subject to re-negotiation after this date.
Prices on parts are those in effect at time of shipment.
Delivery: 12-16 weeks after receipt of order."

The bid invitation required Guaranteed firm price for the period Jan. 1, 1978 through Dec. 31, 1978.

Subsequent to the bid opening the Treaty representative stated that Purchasing misconstrued their bid statement, that Treaty intended only that they would need a blanket order for the full 1978 hydrant requirements. Treaty insists that their bid does not mean what it very clearly says (see page 5 of 7 in the Treaty bid documents), and submitted two (2) letters in support of their contention (see attachment) hereto. However, it is considered improper to accept these after the bid opening.

Attached are the following documents in support of the recommendation for acceptance of Cooper Distributing Co., Inc. bid:

1. Copy of tab sheet.
2. All vendors bids.
3. Purchase Order B-9364.
4. Copy of bid mailing list.

It is urged that in referring this bid to the City Council for enactment of an ordinance, that all of the attached items, together with this memorandum (or copies), be included with the proposed ordinance.

Please make sure that no confirming Purchase Order Number is given to Cooper Distributing Co., Inc. until evidence of Council approval is furnished to the Purchasing Department.

R. A. Winget
R. A. Winget

Approved: *A. C. Lord*

A. C. Lord

CITY OF FORT WAYNE

CITY UTILITIES

DEPARTMENT OF PURCHASES
ROOM 950 CITY-COUNTY BUILDING
NUMBER ONE EAST MAIN STREET
FORT WAYNE, INDIANA 46802

ORIGINAL
PURCHASE ORDER NO. **B-9364**

This number must appear on each pack-
age, packing slip, invoice, bill of lading,
express receipt and correspondence.

DATE October 31, 1977

Cooper Distributing Co., Inc.
3205 North Wells Street
Fort Wayne, Indiana 46808

SHIP TO —

Water Maintenance & Service Dept.
415 East Wallace Street
Fort Wayne, Indiana 46803

MAIL ALL INVOICES TO —
CITY UTILITIES

GENERAL ACCOUNTING
4th FLOOR CITY-COUNTY BUILDING
NUMBER ONE EAST MAIN STREET
FORT WAYNE, INDIANA 46802

INVOICE IN DUPLICATE, INCLUDING
CERTIFICATION AS REQUIRED BY
INDIANA STATE BOARD OF ACCOUNTS

QUANTITY RECEIVED	QUANTITY ORDERED	DESCRIPTION	UNIT PRICE	TOTAL
		Blanket order for fire hydrants requirements for 1978		
	150	Fire Hydrants (Waterous WB-67) add or deduct for each 6" variation in trench depth \$6.00 Discount from included parts List 5%	324.00/ea	\$48,600.00
		Note: Requirements will be released on departmental Purchase Orders, against this blanket order as required by the using department.		
		<u>SUBJECT TO COUNCILMANIC APPROVAL</u>		
		Per Bid Ref. #447 Net 30 F.O.B. Delivered <u>FIRM PRICE</u>		
		RW/pl #4813		

APPROVED
Board of Public Works

Henry P. Wehrenberg
Edward H. Rammer
May G. Scott

NOTE: TERMS OF PAYMENT MUST BE SHOWN ON FACE OF INVOICE. OTHERWISE A 2% CASH DISCOUNT WILL BE TAKEN

BY _____

CITY UTILITIES PURCHASING AGENT

SUBJECT TO CONDITIONS ON REVERSE SIDE

FORM U-33

City Utilities

PURCHASE REQUISITION

Cooper Distributor
3205 N. Wells St.
46808Date Aug. 31, 1977

Please order the following Material for Delivery as Specified:

To be delivered to Water Maintenance & Serv. Dept.Req. No. 4813On or before 415 E. Wacker Dr.P. O. No. B 9364

QUANTITY	DESCRIPTION	DIST. NO.	DEPARTMENT ESTIMATED COST
	Blanket order for fire hydrants requirements for 1978		
150			
150	Fire Hydrants (Waterous) ^{WB-67} \$324 ^{copy}		
	add or deduct for each 6" variation in trench depth \$6.00		\$48,600.00
	Discount from included parts list 5%		
	Subj. to Councilman's Approval		
	Per Bid Ref. # 447		
REMARKS:	Net 30		
	F.O.B. Delivered		
	Firm Price		

Notes: ~~to be~~

Requirements will be released on departmental Purchase Order, against this blanket order as required by the using department.

Water Maint. & Serv.

Water

Sewage

Rear

Bid No. 447 - 150 Fire Hydrants (1978 Requirements)

Bid Opened Wednesday October 19, 1977 at 11:00 A.M.

<u>Vendor</u>	<u>Brand/Type</u>	<u>Unit Price</u>	<u>Est. Total</u>	<u>Parts Disc.</u>	<u>Delivery</u>	<u>Terms</u>
Treaty Company	* Mueller A-414	\$322.24 ea.	\$48,336.00	- 0 -	12-16 wks.	2% 10th Prox. Net 30 days
Cooper Distributing	Waterous WB-67	324.00 ea.	48,600.00	- 5% -	30 days	Net 30 days
E. & H. Utilities	Waterous WB-67	336.00 ea.	50,400.00	- 10% -	(Not stated)	Net 30 days
Amer. Cast Iron	Amer. Darling B62B	353.32 ea.	52,998.00	- 0 -	90 days	Net 30 days
Kennedy Valve	Kennedy K-10B	369.91 ea.	55,486.50	- 10% -	90 days	2% 10 days
Clow Corp.	Eddy Break F2640	487.00 ea.	73,050.00	- 0 -	(Not stated)	Net 30 days

* Replaces Mueller A-419

A. C. Lord
10/31/77

Treaty Municipal Materials

Greenville, Ohio 45331 — P.O. BOX 40 PHONE (513) 548-2181

Dayton, Ohio 45403 — 1049 Springfield St. PHONE (513) 253-8116
(Toledo) Perrysburg, Ohio 43551 — Cor. Eckel & Eckel Jct. Rds. PHONE (419) 874-312
Ft. Wayne, Indiana 46808 — 4020 Wells St. PHONE (219) 484-0739
Indianapolis, Indiana 46219 — 7281 East Thirtieth St. PHONE (317) 545-6088

October 21, 1977

Mr. Alan Lord
City of Fort Wayne
Purchasing Department
City Building
Fort Wayne, Indiana

Re: Fort Wayne Fire Hydrants
Bid Reference, 447.


Dear Mr. Lord:

We are submitting this letter in order to clarify any misunderstanding which might exist in reference to our fire hydrant bid. Our price for hydrants is firm for acceptance by April 1, 1978, for shipment during the year of 1978. Your bid reflects our estimated usage of 150 units. If you would place an order for these 150 units with releases scheduled for various dates in 1978, our contract price would prevail on all hydrants. If, however, you would not place the order after the date shown, it would be subject to any increase the manufacturer might put into effect.

Our suggestion is to order 200 units now and release them based on your need and delivery dates as outlined by our local office.

Thank you in advance for your consideration on this matter.

Very truly yours,


R. H. Lear
President

cc: Bud Henke

RHL:ma

RECEIVED
PURCHASING DEPT.
OCT 27 1977
AM 7:8,9,10,11,12,1,2,3,4,5,6 PM

October 13, 1977

TREATY COMPANY
Box 40
Greenville, OH 45331

Attention: Mr. Jim Williams

Re: City of Fort Wayne, Indiana
Hydrant Requirements
Bids October 19, 1977
Mueller Quotation No. 1736

Dear Jim:

This confirms our phone conversation of October 12 at which time we advised a discount of 36% would be authorized on City of Fort Wayne hydrant requirements for those orders placed no later than April 1, 1978.

We understand that there are an estimated requirement of 150 5-1/4" A-414 Standard Traffic Model Hydrants, 5'6" bury, with 6" mechanical joint inlet.

In pricing the above hydrants please use the price of the A-24007 Standard adding \$12.38 to trade price for traffic features.

With reference to repair parts no price protection is offered and prices in effect at time of your order placement would apply. We are attaching copy of a parts list for this hydrant.

Usual cash terms will apply with full freight allowed to Fort Wayne, and when placing your orders please refer to this quotation.

Yours very truly,

MUELLER CO.

Ralph E. Shafer

RES/brc

Attached

cc/ Mr. Herman Niehaus
Mr. Dave Resler
Mr. G. W. Piper

FORM CP-23 3-66

CITY OF FORT WAYNE

DEPARTMENT OF PURCHASES

Number One Main St., Ft. Wayne, Ind. 46802

INVITATION

Quotations, subject to the conditions on the reverse hereof, are requested on the following list of materials, supplies, equipment or services, for the department as indicated, with delivery to destination as shown below. Quotations shall include all charges for delivery, packing, etc. Address your reply as indicated below.

*Mail all replies and correspondence, etc. to Attn. of A. C. Lord 423-7037

DEPARTMENT OF PURCHASES

Room 470, Number One Main St., Ft. Wayne, Ind. 46802

REQUIRED FOR DELIVERY TO:Department Water Maintenance & Service Dept.or Division 445 East Wallace StreetAddress Ft Wayne, Indiana 46803

RETURN ORIGINAL TO THE CITY—RETAIN DUPLICATE COPY FOR YOUR FILE

Closing Wednesday, October 19, 1977 at 11:00A.M.

Time of Bids

TAKES: THE CITY IS EXEMPT FROM FEDERAL EXCISE AND INDIANA STATE SALES TAX. THE CITY'S INDIANA SALES TAX EXEMPTION CERTIFICATE NUMBER IS NO. 14694. PRICES SHOULD NOT INCLUDE THESE TAXES. See "Instructions to Bidders" No. 16 on reverse hereof for details.

TAX EXEMPT (Unless otherwise indicated)

Quantity	Unit	Materials, Supplies, Equipment or Services	Unit Price	Total Amount
		<u>FIRE HYDRANTS - 1978 Requirements</u>		
		Estimated usage for January 1, 1978 thru December 31, 1978		
		The enclosed Non-Collusion Affidavit must be properly executed and returned as part of your bid.		
		We require a guaranteed firm price for the period January 1, 1978 thru December 31, 1978 and delivery to our yard within 30 days notification of release. This will <u>not</u> be a one time purchase. It is anticipated that release quantities will be 25 to 30 hydrants per release.		
		Your parts list, with discounts, must accompany your bid.		
		A Blanket Purchase Order will be issued to the successful company, after necessary Councilmanic Approval, and the hydrants are to be delivered only upon issuance of departmental purchase orders.		

Bid Bond required ☒ NO ☐ YES Performance Bond ☒ NO ☐ YES
See Instructions Item No. 18 on reverse side hereof.

Terms 0 % cash discount if paid within — days from delivery and acceptance of goods or completion of services.

PROPOSAL OR BID

In compliance with the above invitation for bids and subject to all conditions thereof, the undersigned offers and agrees, if this bid be accepted within a reasonable time from date of closing, to furnish any or all of the items or render such services upon which prices are quoted, in accordance with the specifications applying and as the price set opposite each item.

Delivery of any or all of the items or completion of services indicated shall be made within 90 days from receipt of order.

IMPORTANT

As delivery may be a deciding factor in the award of an order, it is important that bidders furnish the information requested above.

AMERICAN CAST IRON PIPE VALVE CO.
A Division of American Cast Iron Pipe

Name of Company American Cast Iron Pipe
Title Treasurer

Address P. O. Box 2727

City Birmingham, Ala. Date 35202

FIRE HYDRANT SPECIFICATIONS
Section D - Fire Hydrants (Mains)

Fire hydrants used in the construction of water mains shall be of the traffic type and shall be made in accordance with the latest revisions of the American Water Works Association Standards, designation C502; shall have a six (6) inch mechanical joint bell inlet at the base and all jointing accessories in accordance with Section A-4a of these standards; shall open by turning left (counter clockwise); shall have a minimum valve opening of five (5) inches; shall be equipped with O-ring packing, one and one-half (1-1/2) inch pentagon operating nut, one four and one-half (4-1/2) inch pumper and two (2) two and one-half (2-1/2) inch hose connections, all on the plane, and having National Standard Fire Hose threads of four (4) threads and seven and one-half (7-1/2) threads per inch, respectively; and a ground line flange and shall be painted Federal Yellow.

The fire hydrant barrels shall be of sufficient length so as to connect with the hydrant leg, attached to the water main, and so the ground line flange is not less than two (2) inches or more than six (6) inches above the finished grade of the adjacent area.

Each fire hydrant shall be installed with a six (6) inch mechanical joint valve between it and the main to which it is connected. There shall be a twenty four (24) inch nipple of six (6) inch pipe between the valve and the hydrant. The following fire hydrants, or approved equals, are the only fire hydrants which will be accepted for use in connection with water main installations:

BRAND NAME:

CATALOG NO.

Kennedy

K-10B

American - Darling

B-62B

Traverse City

H-1-M

Waterous

WB-67

Mueller

A-419

Estimated Usage - 150

Hydrant Traffic Type 5' 6" Bury..... \$ 353.32

Add or Deduct for each 6" variation in trench depth..... \$ 6.42

Percentage of discount from Included parts list..... \$ None

CITY OF FORT WAYNE

DEPARTMENT OF PURCHASES

Number One Main St., Ft. Wayne, Ind. 46802

INVITATION

Questions, subject to the conditions on the reverse hereof, are requested on the following list of materials, supplies, equipment or services, for the department as mentioned, with delivery to destination as shown below. Questions shall include all charges for delivery, packing, etc. Advise your reply as indicated below.

*Mail all replies and correspondence, etc. to Attn. of A. C. Lord 423-7037 DEPARTMENT OF PURCHASES

Room 470, Number One Main St., Ft. Wayne, Ind. 46802

REQUIRED FOR DELIVERY TO:

Department or Division Water Maintenance & Service Dept.

Address 445 East Wallace Street
Fort Wayne, Indiana 46803

RETURN ORIGINAL TO THE CITY—RETAIN DUPLICATE COPY FOR YOUR FILE

Closing Time of Bids Wednesday, October 19, 1977 at 11:00A.M.

TAXES: THE CITY IS EXEMPT FROM FEDERAL EXCISE AND INDIANA STATE SALES TAX. THE CITY'S INDIANA SALES TAX EXEMPTION CERTIFICATE NUMBER IS NO. 44664. PRICES SHOULD NOT INCLUDE THESE TAXES. See "Instructions to Bidders" No. 10 on reverse hereof for details.

TAX EXEMPT (Unless otherwise indicated)

Quantity	Unit	Materials, Supplies, Equipment or Services	Unit Prices	Total Amount
		<u>FIRE HYDRANTS - 1978 Requirements</u>		
		Estimated usage for January 1, 1978 thru December 31, 1978		
		The enclosed Non-Collusion Affidavit must be properly executed and returned as part of your bid.		
		We require a guaranteed firm price for the period January 1, 1978 thru December 31, 1978 and delivery to our yard within 30 days notification of release. This will not be a one-time purchase. It is anticipated that release quantities will be 25 to 30 hydrants per release.		
		Your parts list, with discounts, must accompany your bid.		
		A Blanket Purchase Order will be issued to the successful company, after necessary Councilmanic Approval, and the hydrants are to be delivered only upon issuance of departmental purchase orders.		

Bid Bond required ☒ NO ☒ YES Performance Bond ☒ NO ☒ YES
See instruction item No. 16 on reverse side hereof.

Terms 0 % cash discount if paid within days from delivery and acceptance of goods or completion of services.

PROPOSAL OR BID

In compliance with the above invitation for bids and subject to all conditions thereof, the undersigned offers and agrees, if this bid be accepted within a reasonable time from date of closing, to furnish any or all of the items or render such services upon which prices are quoted, in accordance with the specifications appearing and as the prices set opposite each item.

Delivery of any or all of the items or completion of services indicated shall be made within days from receipt of order ^{NO}.

IMPORTANT

As delivery may be a deciding factor in the award of an order, it is important that bidders furnish the information requested above.

Signed:

Clow Corporation

James P. Butters ^{President of Company} Sales Rep.
Address 51591 U. S. 31 North
City South Bend, Ind. Date 10-17-77

FIRE HYDRANT SPECIFICATIONS
Section D - Fire Hydrants (Mains)

Fire hydrants used in the construction of water mains shall be of the traffic type and shall be made in accordance with the latest revisions of the American Water Works Association Standards, designation C502; shall have a six (6) inch mechanical joint bell inlet at the base and all jointing accessories in accordance with Section A-4a of these standards; shall open by turning left (counter clockwise); shall have a minimum valve opening of five (5) inches; shall be equipped with O-ring packing, one and one-half (1-1/2) inch pentagon operating nut, one four and one-half (4-1/2) inch pumper and two (2) two and one-half (2-1/2) inch hose connections, all on the plane, and having National Standard Fire Hose threads of four (4) threads and seven and one-half (7-1/2) threads per inch, respectively; and a ground line flange and shall be painted Federal Yellow.

The fire hydrant barrels shall be of sufficient length so as to connect with the hydrant leg, attached to the water main, and so the ground line flange is not less than two (2) inches or more than six (6) inches above the finished grade of the adjacent area.

Each fire hydrant shall be installed with a six (6) inch mechanical joint valve between it and the main to which it is connected. There shall be a twenty four (24) inch nipple of six (6) inch pipe between the valve and the hydrant. The following fire hydrants, or approved equals, are the only fire hydrants which will be accepted for use in connection with water main installations:

<u>BRAND NAME:</u>	<u>CATALOG NO.</u>
Kennedy	K-10B
American - Darling	B-62B
Traverse City	H-1-M
Waterous	WB-67
Mueller	A-419

Estimated Usage - 150

Hydrant Traffic Type 5' 6" Bury.....	\$ <u>487.00</u>
Add or Deduct for each 6" variation In trench depth.....	\$ <u>8.00</u>
Percentage of discount from included parts list.....	\$ <u>None</u>

Note: Our bid is based on furnishing the F-2640 Eddy Break
Flange Hydrant. If not acceptable, prices do not apply.

CITY OF FORT WAYNE

DEPARTMENT OF PURCHASES

Number One Main St., Ft. Wayne, Ind. 46802

INVITATION

Quotations, subject to the conditions on the reverse hereof, are requested on the following list of materials, supplies, equipment or services, for the department as mentioned, with delivery to destination as shown below. Quotations shall include all charges for delivery, packing, etc. Address your reply as indicated below.

*Mail all replies and correspondence, etc. to Attn. of A. C. Lord 423-7037 DEPARTMENT OF PURCHASES

Room 470, Number One Main St., Ft. Wayne, Ind. 46802

REQUIRED FOR DELIVERY TO:

Department or Division Water Maintenance & Service Dept.
445 East Wallace Street

Address Fort Wayne, Indiana 46803

RETURN ORIGINAL TO THE CITY—RETAIN DUPLICATE COPY FOR YOUR FILE

Closing Time of Bid Wednesday, October 19, 1977 at 11:00A.M.

TAXES: THE CITY IS EXEMPT FROM FEDERAL REGISTERS AND INDIANA STATE SALES TAX. THE CITY'S INDIANA SALES TAX EXEMPTION CERTIFICATE NUMBER IS NO. 24602. PRICES SHOULD NOT INCLUDE THESE TAXES. See "Instructions to Bidders" No. 10 on reverse hereof for details.

TAX EXEMPT (Unless otherwise indicated)

Quantity	Unit	Materials, Supplies, Equipment or Services	Unit Price	Total Amount
		<u>FIRE HYDRANTS - 1978 Requirements</u>		
		Estimated usage for January 1, 1978 thru December 31, 1978		
		The enclosed Non-Collusion Affidavit must be properly executed and returned as part of your bid.		
		We require a guaranteed firm price for the period January 1, 1978 thru December 31, 1978 and delivery to our yard within 30 days notification of release. This will not be a one-time purchase. It is anticipated that release quantities will be 25 to 30 hydrants per release.		
		Your parts list, with discounts, must accompany your bid.		
		A Blanket Purchase Order will be issued to the successful company, after necessary Councilmanic Approval, and the hydrants are to be delivered only upon issuance of departmental purchase orders.		

Bid Bond required ☒ YES ☐ NO ☐ Performance Bond ☒ YES ☐ NO ☐
See instruction item No. 10 on reverse side hereof.

Terms 0 % cash discount if paid within 10 days from delivery and acceptance of goods or completion of services.

PROPOSAL OR BID

In compliance with the above invitation for bids and subject to all conditions thereof, the undersigned offers and agrees, if this bid be accepted within a reasonable time from date of closing, to furnish any or all of the items or render such services upon which prices are quoted, in accordance with the specifications applying and at the price set opposite each item.

Delivery of any or all of the items or completion of services indicated shall be made within 30 days from receipt of order.

IMPORTANT

As delivery may be a deciding factor in the award of an order, it is important that bidders furnish the information requested above.

Sign Here:

Conner Dist. Heating Co. - INC.
Name of Company
For R. H. Coyle Title President
Address 8205 N. Wells Street
City Fort Wayne, Ind. Date 10/19/77

Page 1 of 7

Ref. No. 447

Date _____

Date wanted _____

Fund
Appropriation No. _____

FIRE HYDRANT SPECIFICATIONS
Section D - Fire Hydrants (Mains)

Fire hydrants used in the construction of water mains shall be of the traffic type and shall be made in accordance with the latest revisions of the American Water Works Association Standards, designation C502; shall have a six (6) inch mechanical joint bell inlet at the base and all jointing accessories in accordance with Section A-4a of these standards; shall open by turning left (counter clockwise); shall have a minimum valve opening of five (5) inches; shall be equipped with O-ring packing, one and one-half (1-1/2) inch pentagon operating nut, one four and one-half (4-1/2) inch pumper and two (2) two and one-half (2-1/2) inch hose connections, all on the plane, and having National Standard Fire Hose threads of four (4) threads and seven and one-half (7-1/2) threads per inch, respectively; and a ground line flange and shall be painted Federal Yellow.

The fire hydrant barrels shall be of sufficient length so as to connect with the hydrant leg, attached to the water main, and so the ground line flange is not less than two (2) inches or more than six (6) inches above the finished grade of the adjacent area.

Each fire hydrant shall be installed with a six (6) inch mechanical joint valve between it and the main to which it is connected. There shall be a twenty four (24) inch nipple of six (6) inch pipe between the valve and the hydrant. The following fire hydrants, or approved equals, are the only fire hydrants which will be accepted for use in connection with water main installations:

BRAND NAME:

CATALOG NO.

Kennedy

K-10B

American - Darling

B-62B

Traverse City

H-1-M

Waterous

WB-67

Mueller

A-419

Estimated Usage - 150

Hydrant Traffic Type 5' 6" Bury..... \$ 324.00

Add or Deduct for each 6" variation in trench depth..... \$ 6.00

Percentage of discount from included parts list..... \$ 5%

CITY OF FORT WAYNE

DEPARTMENT OF PURCHASES

Number One Main St., Ft. Wayne, Ind. 46802

INVITATION

Quotations, subject to the conditions on the reverse hereof, are requested on the following list of materials, supplies, equipment or services for the department as mentioned, with delivery to destination as shown below. Quotations shall include all charges for delivery, packing, etc. Advise your reply as indicated below.

*Mail all replies and
correspondence, etc. to Attn. of A. C. Lord 423-7037

DEPARTMENT OF PURCHASES

Room 470, Number One Main St., Ft. Wayne, Ind. 46802

REQUIRED FOR DELIVERY TO:

Department
or Division Water Maintenance & Service Dept.

445 East Wallace Street

Address Fort Wayne, Indiana 46803

RETURN ORIGINAL TO THE CITY—RETAIN DUPLICATE COPY FOR YOUR FILE

Closing Wednesday, October 19, 1977 at 11:00A.M.

Time of Bids

TAXES: THE CITY IS EXEMPT FROM FEDERAL EXCISE AND INDIANA STATE SALES TAX. THE CITY'S INDIANA SALES TAX EXEMPTION CERTIFICATE NUMBER IS NO. 34602. PRICES SHOULD NOT INCLUDE THESE TAXES. See "Instructions to Bidders" No. 10 on reverse hereof for details.

TAX EXEMPT (Unless otherwise indicated)

Page 1 of 7Ref. No. 447

Date _____

Date wanted _____

Fund _____

Appropriation No. _____

Quantity	Unit	Materials, Supplies, Equipment or Services	Unit Price	Total Amount
		<u>FIRE HYDRANTS - 1978 Requirements</u>		
		<u>Estimated usage for January 1, 1978 thru December 31, 1978</u>		
		<u>The enclosed Non-Collusion Affidavit must be properly executed and returned as part of your bid.</u>		
		<u>We require a guaranteed firm price for the period January 1, 1978 thru December 31, 1978 and delivery to our yard within 30 days notification of release. This will not be a one-time purchase. It is anticipated that release quantities will be 25 to 30 hydrants per release.</u>		
		<u>Your parts list, with discounts, must accompany your bid.</u>		
		<u>A Blanket Purchase Order will be issued to the successful company, after necessary Councilmanic Approval, and the hydrants are to be delivered only upon issuance of departmental purchase orders.</u>		

Bid Bond required ☐ NO ☐ YES _____ Performance Bond ☐ NO ☐ YES _____

See instruction item No. 16 on reverse side hereof.

Terms net % cash discount if paid within 30 days from delivery and acceptance of goods or completion of services.

PROPOSAL OR BID

In compliance with the above invitation for bids and subject to all conditions thereof, the undersigned offers and agrees, if this bid be accepted within a reasonable time from date of opening, to furnish any or all of the items or render such services upon which prices are quoted, in accordance with the specifications applying and as the price set opposite each item.

Delivery of any or all of the items or completion of services indicated shall be made within _____ days from receipt of order.

IMPORTANT

As delivery may be a deciding factor in the award of an order, it is important that bidders furnish the information requested above.

E & H UTILITY SALES, INC.

For Norman L. Campbell Signature of Company Norman L. Campbell

Address P.O. Box 470 Wheaton, IL Vice-Pres

City Wheaton, IL 60187 Date 10/18/77

FIRE HYDRANT SPECIFICATIONS
Section D - Fire Hydrants (Mains)

Fire hydrants used in the construction of water mains shall be of the traffic type and shall be made in accordance with the latest revisions of the American Water Works Association Standards, designation C502; shall have a six (6) inch mechanical joint bell inlet at the base and all jointing accessories in accordance with Section A-4a of these standards; shall open by turning left (counter clockwise); shall have a minimum valve opening of five (5) inches; shall be equipped with O-ring packing, one and one-half (1-1/2) inch pentagon operating nut, one four and one-half (4-1/2) inch pumper and two (2) two and one-half (2-1/2) inch hose connections, all on the plane, and having National Standard Fire Hose threads of four (4) threads and seven and one-half (7-1/2) threads per inch, respectively; and a ground line flange and shall be painted Federal Yellow.

The fire hydrant barrels shall be of sufficient length so as to connect with the hydrant leg, attached to the water main, and so the ground line flange is not less than two (2) inches or more than six (6) inches above the finished grade of the adjacent area.

Each fire hydrant shall be installed with a six (6) inch mechanical joint valve between it and the main to which it is connected. There shall be a twenty four (24) inch nipple of six (6) inch pipe between the valve and the hydrant. The following fire hydrants, or approved equals, are the only fire hydrants which will be accepted for use in connection with water main installations:

BRAND NAME:

CATALOG NO.

Kennedy

K-10B

American - Darling

B-62B

Traverse City

H-1-M

Waterous

WB-67

Mueller

A-419

Estimated Usage - 150

We are bidding on the Waterous WB-67

Hydrant Traffic Type 5' 6" Bury..... \$ 336.00/ea

Add or Deduct for each 6" variation in trench depth..... \$ 6.95/6"

Percentage of discount from included parts list..... \$ 10%

Alternate bid on shipments of 60 or more

hydrants at a time \$ 322.00/ea

CITY OF FORT WAYNE

DEPARTMENT OF PURCHASES

Number One Main St., Ft. Wayne, Ind. 46802

INVITATION

Quotations, subject to the conditions on the reverse hereof, are requested on the following list of materials, supplies, equipment or services, for the department as mentioned, with delivery to destination as shown below. Quotations shall include all charges for delivery, packing, etc. Advise your reply as indicated below.

*Mail all replies and correspondence, etc. to Attn. of A. C. Lord 423-7037 DEPARTMENT OF PURCHASES

Room 470, Number One Main St., Ft. Wayne, Ind. 46802

REQUIRED FOR DELIVERY TO:

Department or Division Water Maintenance & Service Dept.
445 East Wallace Street

Address Fort Wayne, Indiana 46803

RETURN ORIGINAL TO THE CITY—RETAIN DUPLICATE COPY FOR YOUR FILE

Closing Time of Bids Wednesday, October 19, 1977 at 11:00A.M.

Page 1 of 7

Ref. No. 447

Date _____

Date wanted _____

Fund _____
Appropriation No. _____

TAXES: THE CITY IS EXEMPT FROM FEDERAL EXCISE AND INDIANA STATE SALES TAX. THE CITY'S INDIANA SALES TAX EXEMPTION CERTIFICATE NUMBER IS NO. 3466. PRICES SHOULD NOT INCLUDE THESE TAXES. See "Instructions to Bidders" No. 10 on reverse hereof for details.

TAX EXEMPT (Unless otherwise indicated)

Quantity	Unit	Materials, Supplies, Equipment or Services	Unit Price	Total Amount
		FIRE HYDRANTS - 1978 Requirements		
		Estimated usage for January 1, 1978 thru December 31, 1978		
		The enclosed Non-Collusion Affidavit must be properly executed and returned as part of your bid.		
		We require a guaranteed firm price for the period January 1, 1978 thru December 31, 1978 and delivery to our yard within 30 days notification of release. This will <u>not</u> be a one time purchase. It is anticipated that release quantities will be 25 to 30 hydrants per release.		
		Your parts list, with discounts, must accompany your bid.		
		A Blanket Purchase Order will be issued to the successful company, after necessary Councilmanic Approval, and the hydrants are to be delivered only upon issuance of departmental purchase orders.		

Etd Bond required ☐ NO ☐ YES ☐ Performance Bond ☐ NO ☐ YES ☐

See Instruction Item No. 13 on reverse side hereof.

Terms 2 % cash discount if paid within 10 days from delivery and acceptance of goods or completion of services.

PROPOSAL OR BID

In compliance with the above invitation for bids and subject to all conditions thereof, the undersigned offers and agrees, if this bid be accepted within a reasonable time from date of closing, to furnish any or all of the items or render such services upon which prices are quoted, in accordance with the specifications applying and as the price bid opposite each item.

Delivery of any or all of the items or completion of services indicated shall be made within 90 days from receipt of order.

IMPORTANT

As delivery may be a deciding factor in the award of an order, it is important that bidders furnish the information requested above.

Sign Here:

Kennedy Valve Mfg. Co., Inc.

Anthony C. De Socio, Sr. Name of Company Assistant Secretary

1021 E. Water Street

Address _____

City Elmira, New York 14902 Date 10/11/77

FIRE HYDRANT SPECIFICATIONS
Section D - Fire Hydrants (Mains)

Fire hydrants used in the construction of water mains shall be of the traffic type and shall be made in accordance with the latest revisions of the American Water Works Association Standards, designation C502; shall have a six (6) inch mechanical joint bell inlet at the base and all jointing accessories in accordance with Section A-4a of these standards; shall open by turning left (counter clockwise); shall have a minimum valve opening of five (5) inches; shall be equipped with O-ring packing, one and one-half (1-1/2) inch pentagon operating nut, one four and one-half (4-1/2) inch pumper and two (2) two and one-half (2-1/2) inch hose connections, all on the plane, and having National Standard Fire Hose threads of four (4) threads and seven and one-half (7-1/2) threads per inch, respectively; and a ground line flange and shall be painted Federal Yellow.

The fire hydrant barrels shall be of sufficient length so as to connect with the hydrant leg, attached to the water main, and so the ground line flange is not less than two (2) inches or more than six (6) inches above the finished grade of the adjacent area.

Each fire hydrant shall be installed with a six (6) inch mechanical joint valve between it and the main to which it is connected. There shall be a twenty four (24) inch nipple of six (6) inch pipe between the valve and the hydrant. The following fire hydrants, or approved equals, are the only fire hydrants which will be accepted for use in connection with water main installations:

BRAND NAME:

CATALOG NO.

Kennedy

K-10B

American - Darling

B-62B

Traverse City

H-1-M

Waterous

WB-67

Mueller

A-419

Estimated Usage - 150

Hydrant Traffic Type 5' 6" Bury..... \$ 369.91

Add or Deduct for each 6" variation in trench depth..... \$ 8.10

Percentage of discount from Included parts list..... \$ 10%

SEE DRAWING D-80341-FWI ATTACHED.

CITY OF FORT WAYNE

DEPARTMENT OF PURCHASES

Number One Main St., Ft. Wayne, Ind. 46802

INVITATION

Quotations, subject to the conditions on the reverse hereof, are requested on the following list of materials, supplies, equipment or services, for the department as mentioned, with delivery to destination as shown below. Quotations shall include all charges for delivery, packing, etc. Address your reply as indicated below.

*Mail all replies and correspondence, etc. to Attn. of A. C. Lord 423-7037 DEPARTMENT OF PURCHASES

Page 1 of 7Ref. No. 447

Date _____

Date wanted _____

Room 470, Number One Main St., Ft. Wayne, Ind. 46802

REQUIRED FOR DELIVERY TO:

Department Water Maintenance & Service Dept.
or Division 445 East Wallace Street

Address Fort Wayne, Indiana 46803

Fund _____
Appropriation No. _____

RETURN ORIGINAL TO THE CITY—RETAIN DUPLICATE COPY FOR YOUR FILE

Closing Wednesday, October 19, 1977 at 11:00A.M.
Time of Bids

TAXES: THE CITY IS EXEMPT FROM FEDERAL EXCISE AND INDIANA STATE SALES TAX. THE CITY'S INDIANA SALES TAX EXEMPTION CERTIFICATE NUMBER IS NO. 14508. PRICES SHOULD NOT INCLUDE THESE TAXES. See "Instructions to Bidders" No. 10 on reverse hereof for details.

TAX EXEMPT (Unless otherwise indicated)

Quantity	Unit	Materials, Supplies, Equipment or Services	Unit Price	Total Amount
		<u>FIRE HYDRANTS - 1978 Requirements</u>		
		Estimated usage for January 1, 1978 thru December 31, 1978		
		The enclosed Non-Collusion Affidavit must be properly executed and returned as part of your bid.		
		We require a guaranteed firm price for the period January 1, 1978 thru December 31, 1978 and delivery to our yard within 30 days notification of release. This will <u>not</u> be a one-time purchase. It is anticipated that release quantities will be 25 to 30 hydrants per release.		
		Your parts list, with discounts, must accompany your bid.		
		A Blanket Purchase Order will be issued to the successful company, after necessary Councilmanic Approval, and the hydrants are to be delivered only upon issuance of departmental purchase orders.		

Bid Bond required ☒ NO ☐ YES _____ Performance Bond ☒ NO ☐ YES _____
See page 5. See instruction item No. 19 on reverse side hereof.
Terms % cash discount if paid within days from delivery and acceptance of goods or completion of services.

PROPOSAL OR BID

In compliance with the above invitation for bids and subject to all conditions thereof, the undersigned offers and agrees, if this bid be accepted within a reasonable time from date of closing, to furnish any or all of the items or render such services upon which prices are quoted, in accordance with the specifications applying and at the price set opposite each item.

Delivery of any or all of the items or completion of services indicated shall be made within days from receipt of order.

IMPORTANT

As delivery may be a deciding factor in the award of an order, it is important that bidders furnish the information requested above.

Ezra Hays

The Company/Municipal Division
Name of Company
For Title President
Address 4020 Wells Street

FIRE HYDRANT SPECIFICATIONS
Section 0 - Fire Hydrants (Mains)

Fire hydrants used in the construction of water mains shall be of the traffic type and shall be made in accordance with the latest revisions of the American Water Works Association Standards, designation C502; shall have a six (6) inch mechanical joint bell inlet at the base and all jointing accessories in accordance with Section A-4a of these standards; shall open by turning left (counter clockwise); shall have a minimum valve opening of five (5) inches; shall be equipped with O-ring packing, one and one-half (1-1/2) inch pentagon operating nut, one four and one-half (4-1/2) inch pumper and two (2) two and one-half (2-1/2) inch hose connections, all on the plane, and having National Standard Fire Hose threads of four (4) threads and seven and one-half (7-1/2) threads per inch, respectively; and a ground line flange and shall be painted Federal Yellow.

The fire hydrant barrels shall be of sufficient length so as to connect with the hydrant leg, attached to the water main, and so the ground line flange is not less than two (2) inches or more than six (6) inches above the finished grade of the adjacent area.

Each fire hydrant shall be installed with a six (6) inch mechanical joint valve between it and the main to which it is connected. There shall be a twenty four (24) inch nipple of six (6) inch pipe between the valve and the hydrant. The following fire hydrants, or approved equals, are the only fire hydrants which will be accepted for use in connection with water main installations:

BRAND NAME:

CATALOG NO.

Kennedy

K-10B

American - Darling

B-62B

Traverse City

H-1-M

Waterous

WB-67

Mueller

~~A-419~~

A-414

Estimated Usage - 150

Hydrant Traffic Type 5' 6" Bury..... \$ 322.24

Add or Deduct for each 6" variation in trench depth..... \$ 6.83

Percentage of discount from included parts list..... \$ 0

Terms: 2% 10th Prox, Net 30 days.

Note: Our prices firm through April 1, 1978. Subject to re-negotiation after this date.

Prices on parts are those in effect at time of shipment.

Delivery: 12 to 16 weeks after receipt of order.

Bid Reference No. 447

Date October 19, 1977

Fire Hydrants (W.M. & S.)

Vendors Name & Address

Cards Mailed

Bids Picked Up

Bids Mailed

Kennedy Valve
1021 /S. Water Street
Elmira, New York

Sept. 28, 1977

Traverse City Iron Works
P.O. Box 848
Traverse City, Michigan

Sept. 28, 1977

Waterous Mfg. Company
300 John E. Carrol Avenue
South St. Paul, Minnesota

Sept. 28, 1977

Clow Corporation
51591 U. S. 31 North
South Bend, Indiana

Sept. 28, 1977

Tri State Plumbing
1120 Taylor Street

Sept. 28, 1977

Cooper Distributing
3205 N. Wells Street

Sept. 28, 1977

9/30/77

Treaty Company
4020 Wells Street

Sept. 28, 1977

10/6/77

Traverse City Iron Works
11861 Cottage Grove Ave.
Chicago, Ill. 60628

Sept. 28, 1977

American Cast Iron Pipe Co.
Suite 201 Cherry Creek Office Bldg.
2711 W. 183rd Street
Homewood, Illinois 60430

Sept. 28, 1977

Dresser Mfg. Div.
Dresser Industries Inc.
Bradford, Pa.

Sept. 28, 1977

Midwest Utility
P.O. Box 29156
Cumberland Indiana

9/30/77

ence No. 447

October 19, 1977

Cards Mailed

Bids Picked Up

Bids Mailed

Vendors Name & Address

Water Works Supplies Inc.
P.O. Box 291000
Cumberland, Indiana 46229

9-28-77

3865
PPH

SPECIAL ORDINANCE - CITY UTILITIES BLANKET PURCHASE ORDER NO. B-9364
COOPER DISTRIBUTING CO.

TITLE OF ORDINANCE _____

DEPARTMENT REQUESTING ORDINANCE _____

BOARD OF PUBLIC WORKS

8-77-11-45

SYNOPSIS OF ORDINANCE CITY UTILITIES BLANKET PURCHASE ORDER NO. B-9364 - COOPER DISTRIBUTING

CO. IN THE ESTIMATED AMOUNT OF \$48,600.00 (BID NO. 447)

FOR THE PURCHASE OF 150 FIRE HYDRANTS (1978 REQUIREMENTS)

(SEE MEMORANDUM AND PURCHASE ORDER ATTACHED)

EFFECT OF PASSAGE 1978 REQUIREMENTS FOR FIRE HYDRANTS FOR WATER MAINTENANCE & SERVICE

EFFECT OF NON-PASSAGE SELF-EXPLANATORY

MONEY INVOLVED (DIRECT COSTS, EXPENDITURES, SAVINGS) APPROXIMATE AMOUNT \$48,600.00

FROM CITY UTILITIES

ASSIGNED TO COMMITTEE _____

EP City Utilities